

Emission Test Certificate

Thursday, June 21st, 2012

Supplier: Premium Floors (6 Domic Place, Deeway NSW 2099)

Sample Description: Arc Bamboo

Date Tested: June 2012 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data:

| | |
|---|---|
| Green Building Council of Australia Green Star Office Design IEQ-13 | Arc Bamboo |
| Total Volatile Organic Compound Emission Rate limit <0.5mg/m ² /hr | Total Volatile Organic Compound Emission Rate: <0.008mg/m ² /hr (24 hours) |
| Formaldehyde Compound Emission Rate limit <0.1mg/m ² /hr | Formaldehyde Compound Emission Rate: :<0.021 mg/m ² /hr |



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Anne Saletti
BNanotech/BSc(Hons)
Consultant

CV120535